

**⚠ Before you begin, determine your channel letter module mounting method. ⚠**  
**READ THESE INSTRUCTIONS COMPLETELY AND CAREFULLY.**

**PREPARE ELECTRICAL WIRING**

- Acceptable for use in dry, damp and wet locations.
- Follow all National Electric Codes (NEC) and local codes.
- This product is intended to be installed and serviced by a qualified, licensed electrician.
- Ensure applicable wire is installed between driver, fixture, and any controls in between.
- When choosing wire, factor in voltage drop, amperage rating, and type (in-wall rated, wet location rated, etc.).
- Inadequate wire installation could overheat wires, and cause a fire.
- Do not install if product has any visible damage.
- Do not modify or disassemble this product beyond instructions or the warranty will be void.

**RISK OF ELECTRICAL SHOCK**

- Turn power off before inspection, installation or removal.
- Properly ground power supply.

**RISK OF FIRE**

- Use only UL approved wire for input/output connections.
- Minimum wire size 18 AWG
- Follow all NEC and local codes.

**SHOCK HAZARD. ⚡**

- May result in serious injury or death.
- Turn off power at the circuit breaker before installing

**TOOLS REQUIRED:**



**TOOLS REQUIRED:**

